



PLUMBING PRODUCTS LISTING PROGRAM

Customer: Oakville Stamping & Bending LTD (OS&B®)
Class: Plastic Piping and Accessories
Location: Oakville, Ontario Canada
Website: www.OSB.ca www.osbplumbing.com

Listing No. P365-1
Project No. P365-1
Effective Date: December 31, 2019
Last Revised
Date:
Expires: <N/A>

Standards: CAN/ULC S102.2 *“Method of Test for Surface Burning Characteristics of Flooring, Floor Coverings, and Miscellaneous Materials and Assemblies”.*

Product: FRZERO Plastic Fittings

Markings: Products are marked in a permanent manner where it is readily visible after installation with the following:

- Manufacturer's name or trademark
- Model designation
- QAI file Number: P365-1
- Standard: CAN/ULC S102.2
- Flame Spread Rating 0, Smoke Developed Rating 40
- Warning markings as required by the standards in English and French
- QAI logo shown here:





Models:

| Model Description | Sizes | |
|---|---------------|--------------|
| | Min. Diameter | Max Diameter |
| 9311 FRZERO Sanitary Tee | 1 ½-inch | 1 ½-inch |
| 9316-L Waste Shoe | 1 ½-inch | 1 ½-inch |
| 9317 Direct Tee | 1 ½-inch | 1 ½-inch |
| 9642 Overflow Elbow | 1 ½-inch | 1 ½-inch |
| AA11-FRZERO Angle Adapter | 1 ½-inch | 1 ½-inch |
| SD25-BASE for Shower Drains and Island Tub Drains | 1 ½-inch | 2-inch |
| SD9-BASE FRZERO shower base for tile | 1 1/2-inch | 2-inch |
| SD9-COLLAR clamp collar for SD9-BASE | 1-1/2-inch | 2- inch |

NOTE 1: 9311, 9642, 9316-L, AA11 used in OS&B bath drain models 2550.

NOTE 2: 9317, 9642, AA11 used in OS&B bath drain models 25D.

NOTE 3: SD25-BASE used in OS&B shower drain model SD25 and in Island Tub Drain model ITD25.

NOTE 4: SD9-BASE, SD9-COLLAR used in OS&B shower drain model SD24 and SDS24.

Ratings: The following outlines the performance of the OS&B Fittings noted in the Models table in accordance with the noted standards.

CAN/ULC S102.2 – Surface Burning Characteristics

| Limitations | Flame Spread Index | Smoke Developed Index |
|---|--------------------|-----------------------|
| Maximum 2-inch nominal diameter fittings. No spacing requirements between fittings. | 0 | 40 |

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.